



Pismo Beach
R3-2004-0051

Monthly eSMR SUMMARY

Expected Requirements:

Pismo Beach
R3-2004-0051

M-001

Flow	1 / Day	MGD
Chlorine, Total Residual	1 / Day	mg/L
Chlorine Usage	1 / Day	lb/day
Total Coliform	2 / Week	MPN/100 mL
Fecal Coliform	5 / Week	MPN/100 mL
Temperature	1 / Week	Degrees C
Turbidity	1 / Week	NTU
Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
BOD5 @ 20 Deg. C, Percent Removal	1 / Month	%
Total Suspended Solids (TSS)	1 / Week	mg/L
Total Suspended Solids (TSS), Percent Removal	1 / Month	%
pH	1 / Week	SU
Settleable Solids	1 / Week	ml/L
Oil and Grease	1 / Week	mg/L

M-INF

Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1 / Week	mg/L
Total Suspended Solids (TSS)	1 / Week	mg/L

Using Narratives Tab:

M-001

Fecal Coliform: The 7-sample median shall not exceed 200 MPN/100 ml. (Final requirement effective null - null)[All year]

Using Raw Data Tab:

N/A